

Town of Eastend Annual Notice to Consumers

The Water Security Agency requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by the Town's Permit to Operate a Waterworks. The following is a summary of the Town of Eastend water quality and sample submission compliance record for the January 1 to December 31, 2025, period. This report was completed on January 28, 2026. If consumers need more information on the nature and significance of specific water tests, please contact the Town or the Water Security Agency.

Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform	0 Organisms/100 mL	52	52	0
E. coli	0 Organisms/100 mL	52	52	0

Disinfection – Chlorine Residual in Distribution System Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	.69 – 1.31	.67 – 1.28	52	52	100%

Disinfection - Free Chlorine Residual for Water Entering Distribution System at Water Treatment Plant

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.4	0.63 – 1.29	365	0

The Town's permit to operate requires a specific minimum free chlorine residual for water entering the distribution system. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirements as stated in the Town's Permit to Operate.

Turbidity – From Water Treatment Plant Records

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	0.1	.02 - .06	0	0.06	365	365

Chemical – Health Category

The Town of Eastend is required to submit water samples for WSA's Chemical Health category once per year. The last sample for Chemical Health analysis was submitted on January 9, 2025. Sample results indicated that the provincial drinking water quality standards were not exceeded.

Parameter	Limit MAC(mg/L)	Limit IMAC (mg/L)	Sample Result(s)	# Samples Exceeding Limit
Aluminum	NA		<0.000696	0
Antimony	NA		<0.00016	0
Arsenic	0.010		0.00010	0
Barium	1.0		0.0013	0
Boron	5.0		<0.1	0
Cadmium	0.005		<0.00015	0
Chromium	0.05		<0.00019	0
Copper	1.0		0.0183	0
Iron	0.3		<0.1	0
Lead	0.01		0.00010	0
Manganese	.05		<0.01	0
Selenium	0.01		0.00113	0



**Saskatchewan
Ministry of
Environment**



Silver	NA	<0.00020	<u>0</u>
Uranium	0.02	0.0002	<u>0</u>
Zinc	5.0	<0.004	<u>0</u>

Chemical – Trihalomethanes (THMs) and Haloacetic Acids (HAAs)

Parameter	THMs Limit (mg/L)	Sample Result (average)	# Samples Required	# Samples Submitted
Trihalomethanes	0.1		0	0
Haloacetic Acids	0.08		0	0

The next samples are due in 2026.

General Chemical

Parameter	Aesthetic Objectives * (mg/L)	Sample Results(2023)	# Samples Required	# Samples Submitted
Alkalinity	<500	<u>40.9</u>	<u>1</u>	<u>1</u>
Bicarbonate	No Objective	<u>50.0</u>	<u>1</u>	<u>1</u>
Calcium	No Objective	<u>6.0</u>	<u>1</u>	<u>1</u>
Carbonate	No Objective	<u>0.0</u>	<u>1</u>	<u>1</u>
Chloride	<250	<u>2.5</u>	<u>1</u>	<u>1</u>
Conductivity	<2300	<u>99.0</u>	<u>1</u>	<u>1</u>
Hardness	<800	<u>27.0</u>	<u>1</u>	<u>1</u>
Magnesium	<.05	<u>3.0</u>	<u>1</u>	<u>1</u>
PH	7.0 – 10.5	<u>7.7</u>	<u>1</u>	<u>1</u>
Sodium	<300	<u>8.0</u>	<u>1</u>	<u>1</u>
Sulphate	<500	<u>6.8</u>	<u>1</u>	<u>1</u>
Total dissolved Solids	<1500	<u>78.0</u>	<u>1</u>	<u>1</u>

The Town of Eastend is required to submit water samples once per year. The last sample for General Chemical analysis was submitted on January 9, 2025.

More information on water quality and sample submission performance may be obtained from:

Town of Eastend
PO Box 520
Eastend, SK S0N 0T0
Ph: 306-295-3322 Fax: 306-295-3571
eastend@sasktel.net



**Saskatchewan
Ministry of
Environment**

